



# CERTIFICATE OF CONFORMITY

This is to certify that

## The Nuraply 3PC Carpark Waterproofing System

### Complies with the New Zealand Building Code:

Performance Clauses B1.3.2 and B1.3.3 (e) and (m)

Performance Clauses B2.3.1 (b) and B2.3.2 (a)

Performance Clause E2.3.2

Performance Clause F2.3.1.

Compliance with other clauses have been considered and found not applicable.

### Subject to the following:

#### Limitations of use -

A. All designs and construction shall be within the requirements and the tables set out in the Nuraply 3PC Carpark Waterproofing Technical manual 2017 edition 2 available from the manufacturer's web site [www.nuralite.co.nz](http://www.nuralite.co.nz); and, all other uses are outside the scope of this certificate.

B. Accessories, componentry, cladding and finishing systems to comply with that specified in the Nuraply 3PC Carpark Waterproofing Technical manual 2017 and the Nuraply Waterproofing Membrane Building Product Quality Plan (2015 -v1);

C. Installation shall be performed by Nuralite Waterproofing Ltd trained and approved installers, who shall be supervised by a suitably qualified Licensed Building Practitioner;

D. Installation and maintenance - where required - of the Carpark Waterproofing system, shall be in accordance with the Nuraply Waterproofing Membrane Building Product Quality Plan, available on request;

#### Conditions of certification -

E. The Building Product Quality Plan for the Nuraply Carpark Waterproofing System shall be reviewed and subject to audit at their head office and building sites by the issuer at least once a year;

F. This CodeMark Certificate shall be revalidated on an annual basis;

H. This CodeMark Certificate is subject to S15 of the Building Product Certification Regulations 2008.

### Technical information:

Information that forms part of this certificate or the basis for certification is available from the issuer on request and may be subject to a fee.

Note that this certificate may only be reproduced in its entirety.



[www.jas-anz.org/register](http://www.jas-anz.org/register)

### Product description

The Nuraply 3PC roofing membrane system comprises of Nuraflux primer, Nuraply 3PB Reinforcing Strip, Nuraply 3PC and Nuraply 3PM, together with specified accessories as required by each project. When installed, the system has a bitumastic hot mix applied over it by others to provide a durable water-proof car-park substrate.

### Product purpose or use

The Nuraply 3PC torch-on membrane provides a durable waterproofing system for installation of a bitumastic hotmix substrate suitable for vehicular traffic, by approved installers, on new and existing concrete rooftop carpark decks of any size.

### Certificate Holder

**Nuralite waterproofing Ltd.**  
53A Victoria Street  
Onehunga Auckland 1061.  
Phone 09 579 2046

### CodeMark Certification Body

BEAL Certification Service Limited  
2A Plimmerton Drive  
Plimmerton, Porirua 5026, NZ  
Phone: +64 4 233 6661  
E-Mail: [bcs@beal.co.nz](mailto:bcs@beal.co.nz)  
Website: [www.beal.co.nz](http://www.beal.co.nz)

**C R Prouse**  
Director  
BEAL Certification Service

10 March 2017

Date of issue

BCS-143517-CMNZ

Certificate Number